

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400 Fax (03) 9371 2499

## TEST REPORT

**Client :** Victoria Carpet Co Pty Ltd  
7-29 Gladstone Road  
Dandenong VIC 3175

**Test Number :** 15-002320  
**Issue Date :** 05/06/2015  
**Print Date :** 5/06/2015  
**Order Number :** 51668

**Sample Description** Clients Ref : "Tullibrook"  
Cut pile tufted carpet  
Colour : Brown  
Nominal Composition : 80% Wool, 20% Synthetic

AS 4586-2013  
Appendix A

### Slip Resistance Classification of New Pedestrian Surface Materials Wet Pendulum Test Method

Specimen	British Pendulum Number
1	58
2	59
3	62
4	56
5	55
Slip Resistance Value (SRV)	58

Classification P5-Surface tested dry  
Preparation As received  
Fixed/Unfixed Unfixed  
Air Temperature 22 °C

Test Equipment: Munro Stanley Skid resistance Tester (Pendulum) Serial number: 0320  
Slider rubber: Slider 96 Batch No. 59, prepared on a P400 and 3 µm lapping film  
These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

Tested by ATTAR

26116

4987

Page 1 of 1

© Australian Wool testing Authority Ltd  
Copyright - All Rights Reserved

Samples, and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. The above test results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY.

This document shall not be reproduced except in full and shall be rendered void if amended or altered.

This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)  
MANAGING DIRECTOR